



INSTITUT PRO TESTOVÁNÍ A CERTIFIKACI, a.s.
třída Tomáše Bati 299, Louky, 763 02 Zlín, Česká republika
Divize CSI – Centrum stavebního inženýrství



AUTORIZOVANÁ OSOBA č. 224

Rozhodnutí o autorizaci č. 11/2023 ze dne 7. srpna 2023

vydává

CERTIFIKÁT VÝROBKU
č. 05 0364 V/AO/j

V souladu s ustanoveními §5, odst. 2, nařízení vlády č. 163/2002 Sb., kterým se stanoví technické požadavky na vybrané stavební výrobky, ve znění Nařízení vlády č. 312/2005 Sb. a Nařízení vlády 215/2016 Sb. (NV 163), Autorizovaná osoba č. 224 potvrzuje, že u stavebního výrobku

Trubky PE 100 (ELTEX TUB 121, FINATHENE XS 10 B, BorSafe HE3490-LS, Hostalen CRP 100 Black, Hostalen CRP 100 Black XL, Sabcic VESTOLEN A 6060 R 10000, Sabcic P6006AD black, Liten PL 62-005), d 20 mm – d 500 mm, PN 6 – PN 25 pro tlakové rozvody pitné vody (W), vody pro všeobecné účely, kanalizační přípojky a stokové sítě tlakové a podtlakové (P) d 560 mm – d 1200 mm, PN 6 – PN 25 pro tlakové rozvody vody pro všeobecné účely, kanalizační přípojky a stokové sítě tlakové a podtlakové (P)

**Trubky PE 100 RC,
Trubky PE 100 RC-H PAS 1075,
Trubky PE 100 RC PAS 1075,
d 20 mm – d 500 mm, PN 6 – PN 25,
pro tlakové rozvody pitné vody (W), vody pro všeobecné účely, kanalizační přípojky a stokové sítě tlakové a podtlakové (P)**

uváděného na trh společností

LUNA PLAST a. s.
Hořín 93, 276 01 Mělník, Česká republika
DIČ: CZ25546945

z místa výroby

LUNA PLAST a. s.
Hořín 93, 276 01 Mělník, Česká republika


přezkoumala předložené podklady, provedla počáteční zkoušku typu výrobku na vzorku a posoudila způsob kontroly výrobků a zjistila, že uvedený výrobek splňuje základní požadavky nařízení vlády, konkretizované v určené normě **ČSN EN 12201-2+A1**.

Autorizovaná osoba č. 224 zjistila, že způsob kontroly výrobků odpovídá příslušné technické dokumentaci a zabezpečuje, aby výrobky dodávané na trh splňovaly požadavky stanovené shora uvedenými technickými normami a odpovídaly technické dokumentaci podle §4, odst. 3, NV 163.

Certifikát byl vydán na základě Protokolu o certifikaci č. **795200163/2024** ze dne 13. 3. 2024, který obsahuje závěry zjišťování a ověřování, výsledky zkoušek a základní popis výrobku, nezbytný pro jeho identifikaci.

Tento certifikát zůstává v platnosti po dobu, po kterou se požadavky stanovené v technických předpisech nebo normách, na které byl uveden odkaz, nebo výrobní podmínky v místě výroby či způsob kontroly výrobků výrazně nezmění.

Autorizovaná osoba č. 224 provádí nejméně jedenkrát za 12 měsíců dohled nad řádným fungováním kontroly výrobků, odebírá vzorky výrobků, provádí jejich zkoušky a posuzuje, zda vlastnosti výrobku odpovídají normám podle ustanovení §5, výše uvedeného nařízení vlády. Pokud autorizovaná osoba č. 224 zjistí nedostatky, je oprávněna zrušit nebo změnit tento certifikát.



Vydáno ve Zlíně: **22-06-2005**

Změna j): **13-03-2024**

(Nahrazuje certifikát č. 05 0364 V/AO/i ze dne 21-06-2021)

Mgr. Jiří Heš

z
představitel Autorizované osoby č. 224



INSTITUT PRO TESTOVÁNÍ A CERTIFIKACI, a.s.
třída Tomáše Bati 299, Louky, 763 02 Zlín, Czech Republic
Division CSI – Centre of Civil Engineering



AUTHORIZED BODY NO. 224

Authorization granted by the Decision No. 11/2023 dated 7th August 2023

Issues

PRODUCT CERTIFICATE
No. 05 0364 V/AO/j

In compliance with the provision of Section 5, Subsection 2 of the Government Order No. 163/2002, Collection of Laws, as amended by the Government Order No. 312/2005, Collection of Laws and Government Order No. 215/2016, Collection of Laws (hereafter GO 163), which lays down technical requirements for selected building products, the Authorized Body No. 224 confirms that for the construction product

PE 100 Pipes (ELTEX TUB 121, FINATHENE XS 10 B, BorSafe HE3490-LS, Hostalen CRP 100 Black, Hostalen CRP 100 Black XL, Sabcic VESTOLEN A 6060 R 10000, Sabcic P6006AD black, Liten PL 62-005), d 20 mm – d 500 mm, PN 6 – PN 25, for pressure distribution of drinking water (W), water for general purposes, waste connections and sewerage systems under pressure (P), d 560 mm – d 1200 mm, PN 6 – PN 25, for pressure water distribution for general purposes, waste connections and sewerage systems under pressure

**Trubky PE 100 RC,
Trubky PE 100 RC-H PAS 1075,
Trubky PE 100 RC PAS 1075,
d 20 mm – d 500 mm, PN 6 – PN 25, for pressure distribution of drinking water (W), water for general purposes, waste connections and sewerage systems under pressure (P)**

placed on the market by the company

LUNA PLAST a. s.
Hořín čp. 13, 276 01 Mělník, Czech Republic
VAT No: CZ25546945

from the site of manufacture

LUNA PLAST a. s.
Hořín čp. 13, 276 01 Mělník, Czech Republic

it has reviewed the documents submitted by the applicant, carried out the initial type testing on a sample and assessed the factory production control. The Authorized Body No. 224 ascertained conformity of the product properties with essential requirements of the GO 163, which are specified by technical standard **ČSN EN 12201-2+A1**.

Further, the Authorized Body No. 224 ascertained that the factory production control complies with the submitted technical documentation and ensures that the products placed on the market fulfil the requirements laid down by the above mentioned norms and by the technical documentation pursuant to Section 4, Subsection 3 of the GO 163, as amended.

This Certificate was issued on the basis the Certification Report No. **795200163/2024** dated 2024-03-13 containing conclusions of the assessment, the test results obtained and basic description of the product, as necessary for its identification.

This Certificate remains valid as long as the requirements laid down in the technical documentation and/or norms in reference or the manufacturing conditions in the factory or the FPC itself are not modified significantly.

The Authorized Body No. 224 performs at least once per year a surveillance of the factory production control, takes samples of the product and by the way of testing it finds out, if the product properties comply with the requirements of the norms according to the Section 5 of the mentioned Government Order. If the Authorized Body finds any shortcomings it has the right to cancel or amend the Certificate it has issued.

Issued in Zlín on **2005-06-22**

Revision j): **2024-03-13**

Replaces the withdrawn certificate No. 05 0364 V/AO/i issued on 2021-06-21)

Mgr. Jiří Heš

Representative of the Authorized Body No. 224